

**15-DAY EXPRESS TERMS  
FOR  
PROPOSED BUILDING STANDARDS  
OF THE  
CALIFORNIA BUILDING STANDARDS COMMISSION**

**REGARDING PROPOSED CHANGES TO THE  
2016 CALIFORNIA GREEN BUILDING STANDARDS CODE  
CALIFORNIA CODE OF REGULATIONS, TITLE 24, PART 11**

***Legend for Express Terms:***

1. **Existing California amendment:** California 45-Day language will appear in underlined and ~~strikeout~~.
2. **Amended, or repealed language:** Amended or repealed 15-Day language will appear in *italics and double underline* and ~~double strikeout~~.
3. **Rationale:** The justification for the change is shown after each section or series of related changes.
4. **Notation:** Authority and reference citations are provided at the end of each chapter.

**EXPRESS TERMS**

1. **BSC proposes to amend Chapter 2 as follows:**

**SECTION 202  
DEFINITIONS**

**RECYCLED WATER SUPPLY SYSTEM. [BSC-CG]** The building supply pipe, the water distribution pipes, and the necessary connecting pipes, fittings, control valves, backflow prevention devices, and all appurtenances carrying or supplying reclaimed (recycled) water in or adjacent to the building or within the premises.

**Notation:**

Authority: Health and Safety Code Sections 18928, 18930.5, 18934.5, and 18940.6

Reference: Health and Safety Code Section 18928.1 and 18940.6

**Rationale:** Based on 45-day public comment, CBSC is proposing this editorial change to align with similar amendments coordinated with the Department of Housing and Community Development (HCD) and the Department of Water Resources (DWR). This also corresponds to an identical amendment CBSC is proposing for the California Plumbing Code. There is no intended change in regulatory effect.